



**Protect Membranes**  
2 Brooklands Road, Sale, Cheshire M33 3SS

Telephone **0161 905 5700**  
Fax **0161 905 2085**  
Email **info@protectmembranes.com**  
Website **www.protectmembranes.com**

**U-value calculation**

by BRE U-value Calculator version 2.03  
Printed on 06 Mar 2018 at 15:32

**Element type: Roof - Structural insulated panel**  
Calculation Method: BS EN ISO 6946

**Roof Type 2 - 219mm SIP**

Layer	d (mm)	λ layer	λ bridge	Fraction	R layer	R bridge	Description
					0.100		Rsi
1	50	0.021			2.381		Gyproc Thermaline Super
2	25	R-value <sup>1</sup>	0.120	0.0800	0.780	0.208	Air layer unventilated
3							Protect VC Foil Ultra Insulating AVCL
Membrane							
4	11	0.130			0.085		SIP - OSB
5	197	0.030			6.567		SIP - Lambdatherm EPS
6	11	0.130			0.085		SIP - OSB
7							Protect VP400 Plus LR
8	50	R-value					Air layer ventilated
9	12	1.000					Roof Tiles
					<u>0.100 #</u>		Rse
	<u>356 mm (total roof thickness)</u>				10.097		

<sup>1</sup>Specified thermal resistance

# this resistance substitutes for Rse and the resistance of layers 8-9 because of the ventilated air layer (layer 8)

Total resistance: Upper limit: 10.049 Lower limit: 9.956 Ratio: 1.009 Average: 10.003 m<sup>2</sup>K/W

U-value 0.100  
**U-value (rounded) 0.10 W/m<sup>2</sup>K**

The U value result has been determined as follows:

**Bridging:**

A thermal bridge percentage for the timber studs of 12.5% has been used in accordance with BR 443: 2006 Conventions for U values (section 4.5.1 (ii)).

**Correction level:**

A correction level of 0 has been used in accordance with Table F1 of BS EN ISO 6946: 2017 Building components and Building elements - Thermal transmittance - Calculation methods.

Please check to confirm and advise if any amendments are required.

Calculated by Protect Technical Services

