



**Protect Membranes**  
2 Brooklands Road, Sale, Cheshire M33 3SS

Telephone **0161 905 5700**  
Fax **0161 905 2085**  
Email [info@protectmembranes.com](mailto:info@protectmembranes.com)  
Website [www.protectmembranes.com](http://www.protectmembranes.com)

### Calculation of interstitial condensation

by ICond Calculator version 2.03

Printed on 02 Mar 2018 at 15:12

#### Element type: Wall

Calculation Method: BS EN ISO 13788

#### Wall Type 3 - 194mm SIP

#### Construction Details

Layer	d mm	$\lambda$ W/m·K	rv MN·s/g·m	R layer m <sup>2</sup> K/W	Rv layer MN·s/g	Description
				0.130		Rsi
1	12.5	0.210	60.0	0.060	0.75	Vapour Check Plasterboard
2			Rv-value		689	Protect VC Foil Ultra Insulating AVCL m
3	25	R-value	Rv-value	0.780	0.050	Cavity unventilated
4	11	0.130	50.0	0.085	0.55	SIP - OSB
5	172	0.030	5.00	6.880	0.86	SIP - Lambdatherm EPS
6	11	0.130	50.0	0.085	0.55	SIP - OSB
7			Rv-value		1.0	Protect TF200 Breather Membrane
8	50	R-value	Rv-value		##	Cavity ventilated
9	18	0.125			##	Timber Cladding
				<u>0.130 #</u>		Rse
	<u>300 mm (total wall thickness)</u>			8.149	693	

# this resistance substitutes for Rse and the resistance of layers 8-9 because of the ventilated air layer (layer 8)

## set to zero because of the ventilated air layer

#### Boundary conditions

Manchester (Edinburgh.hgt)

Return period 2 years (mean external temperature and RH)

Internal Humidity: BS 5250 Class 3

#### Results

No condensation

The U value result has been determined as follows:

#### Bridging:

A thermal bridge percentage for the timber studs of 12.5% has been used in accordance with BR 443: 2006 Conventions for U values (section 4.5.1 (ii)).

#### Correction level:

A correction level of 0 has been used in accordance with Table F1 of BS EN ISO 6946: 2017 Building components and Building elements - Thermal transmittance - Calculation methods.

Please check to confirm and advise if any amendments are required.

Calculated by Protect Technical Services





**protect**

**Protect Membranes**

2 Brooklands Road, Sale, Cheshire M33 3SS

Telephone **0161 905 5700**

Fax **0161 905 2085**

Email [info@protectmembranes.com](mailto:info@protectmembranes.com)

Website [www.protectmembranes.com](http://www.protectmembranes.com)