



Protect Membranes
2 Brooklands Road, Sale, Cheshire M33 3SS

Telephone **0161 905 5700**
Fax **0161 905 2085**
Email info@protectmembranes.com
Website www.protectmembranes.com

U-value calculation

by BRE U-value Calculator version 2.03
Printed on 02 Mar 2018 at 10:57

Element type: Wall - Structural insulated panel

Calculation Method: BS EN ISO 6946

Wall Type 1 - 119mm SIP Value

Layer	d (mm)	λ layer	λ bridge	Fraction	R layer	R bridge	Description
					0.130		Rsi
1	12.5	0.210			0.060		Plasterboard
2	25	R-value ¹	0.130	0.125	0.780	0.192	Cavity unventilated
3							Protect VC Foil Ultra Ins AVCL Membrane
4	11	0.130			0.085		SIP - OSB
5	97	0.030			3.233		SIP - Lambdatherm EPS
6	11	0.130			0.085		SIP - OSB
7							Protect TF200 Thermo Ins Breather Membrane
8	60	R-value ²			0.770		Cavity unventilated
9	102.5	0.770			0.133		Brick outer leaf
					<u>0.040</u>		Rse
	<u>319 mm</u> (total wall thickness)				<u>5.315</u>		

¹Specified thermal resistance

²Specified thermal resistance

Total resistance: Upper limit: 5.234 Lower limit: 5.100 Ratio: 1.026 Average: 5.167 m²K/W

U-value 0.194

U-value (rounded) 0.19 W/m²K

The U value result has been determined as follows:

Bridging:

A thermal bridge percentage for the timber studs of 12.5% has been used in accordance with BR 443: 2006 Conventions for U values (section 4.5.1 (ii)).

Correction level:

A correction level of 0 has been used in accordance with Table F1 of BS EN ISO 6946: 2017 Building components and Building elements - Thermal transmittance - Calculation methods.

Please check to confirm and advise if any amendments are required.

Calculated by Protect Technical Services

